

October 29, 2004

Mr. A. Christopher Bakken, III
President & Chief Nuclear Officer
PSEG Nuclear, LLC - N09
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: HOPE CREEK GENERATING STATION - CORRECTION OF AMENDMENT
NO.156 RE: REVISION TO CONTROL ROOM EMERGENCY FILTRATION
SYSTEM TECHNICAL SPECIFICATIONS (TAC NO. MC1683)

Dear Mr. Bakken:

On October 28, 2004, the Commission issued Amendment No. 156 to Facility Operating License No. NPF-57 for the Hope Creek Nuclear Generating Station. That amendment removed the technical specification (TS) operability requirements for the Control Room Emergency Filtration System during core alterations and the movement of sufficiently decayed irradiated fuel.

Subsequent to the issuance of Amendment No. 156, PSEG identified an error that had been inadvertently introduced into the text of TS 3.7.2.b.1 (TS page 3/4 7-6) that was issued with the amendment. Specifically, the limiting condition for operation (LCO) ACTION time for "OPERATIONAL CONDITION *:" was inadvertently changed from 7 days to 30 days. Revisions to the content of this LCO text were not included within the scope of this amendment, and the ACTION time should have remained at 7 days. Enclosed is a corrected page 3/4 7-6. Please replace the page that was issued with the amendment.

Sincerely,

/RA/

Daniel S. Collins, Sr. Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosure: As stated

cc w/encl: See next page

October 29, 2004

Mr. A. Christopher Bakken, III
President & Chief Nuclear Officer
PSEG Nuclear, LLC - N09
Post Office Box 236
Hancocks Bridge, NJ 08038

SUBJECT: HOPE CREEK GENERATING STATION - CORRECTION OF AMENDMENT
NO.156 RE: REVISION TO CONTROL ROOM EMERGENCY FILTRATION
SYSTEM TECHNICAL SPECIFICATIONS (TAC NO. MC1683)

Dear Mr. Bakken:

On October 28, 2004, the Commission issued Amendment No. 156 to Facility Operating License No. NPF-57 for the Hope Creek Nuclear Generating Station. That amendment removed the technical specification (TS) operability requirements for the Control Room Emergency Filtration System during core alterations and the movement of sufficiently decayed irradiated fuel.

Subsequent to the issuance of Amendment No. 156, PSEG identified an error that had been inadvertently introduced into the text of TS 3.7.2.b.1 (TS page 3/4 7-6) that was issued with the amendment. Specifically, the limiting condition for operation (LCO) ACTION time for "OPERATIONAL CONDITION *:" was inadvertently changed from 7 days to 30 days. Revisions to the content of this LCO text were not included within the scope of this amendment, and the ACTION time should have remained at 7 days. Enclosed is a corrected page 3/4 7-6. Please replace the page that was issued with the amendment.

Sincerely,

/RA/

Daniel S. Collins, Sr. Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-354

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	JClifford	EMarinos	CHarbuck	ECoby, RGN-I
ACRS	DCollins	GMatakas, RGN-I	GHill (2)	CRaynor
OGC	PDI-2 Reading	GMiller	HGarg	TBoyce
DLPM DPR				

ACCESSION NO: ML043030571

NRR-106

OFFICE	PDI-2/PM	PDI-2/LA	PDI-2/SC
NAME	DCollins	MO'Brien for CRaynor	AHowe for JClifford
DATE	9/29/04	10/29/04	10/29/04

OFFICIAL AGENCY RECORD

Hope Creek Generating Station

cc:

Mr. John T. Carlin
Vice President - Nuclear Assessment
PSEG Nuclear - N10
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Patrick S. Walsh
Vice President - Eng/Tech Support
PSEG Nuclear - N28
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. Michael Brothers
Vice President - Site Operations
PSEG Nuclear - N10
P.O. Box 236
Hancocks Bridge, NJ 08038

Mr. James A. Hutton
Plant Manager
PSEG Nuclear - X15
P.O. Box 236
Hancocks Bridge, NJ 08038

Ms. Christina L. Perino
Director - Licensing & Nuclear Safety
PSEG Nuclear - N21
P.O. Box 236
Hancocks Bridge, NJ 08038

Jeffrie J. Keenan, Esquire
PSEG Nuclear - N21
P.O. Box 236
Hancocks Bridge, NJ 08038

Ms. R. A. Kankus
Joint Owner Affairs
Exelon Generation Company, LLC
Nuclear Group Headquarters KSA1-E
200 Exelon Way
Kennett Square, PA 19348

Lower Alloways Creek Township
c/o Mary O. Henderson, Clerk
Municipal Building, P.O. Box 157
Hancocks Bridge, NJ 08038

Dr. Jill Lipoti, Asst. Director
Radiation Protection Programs
NJ Department of Environmental
Protection and Energy
CN 415
Trenton, NJ 08625-0415

Brian Beam
Board of Public Utilities
2 Gateway Center, Tenth Floor
Newark, NJ 07102

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector
Hope Creek Generating Station
U.S. Nuclear Regulatory Commission
Drawer 0509
Hancocks Bridge, NJ 08038